DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/10/2015 FORM APPROVED OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 | | | DATE SURVEY COMPLETED |
|---|---|---|--|--|--|--------------------------|
| | | 155150 | B. WING | | | 11/05/2015 |
| NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR | | | | STREET ADDRESS, CITY, STATE, ZIP CODE 640 W ELLSWORTH ST COLUMBIA CITY, IN 46725 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | | ID PREFIX TAG | (EACH CORRECTIVE ACTION | PROVIDER'S PLAN OF CORRECTION (X (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) (X COMPL DAY DAY DAY DEFICIENCY) | |
| K 000 | INITIAL COMMENTS | | K 0 | 00 | | |
| | A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 11/05/15 Facility Number: 000071 Provider Number: 155150 AIM Number: 100273140 At this Life Safety Code survey, Miller's Merry Manor was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This two story facility was determined to be of Type II (222) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridor and battery operated smoke detectors in the resident rooms. The facility has a capacity of 84 and had a census of 61 at the time of this survey. All areas where the residents have customary access are sprinklered. The facility does have a shed providing facility services that was not sprinklered. Quality Review completed on 11/09/15 - DA | | | | | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.